

Ring W. Lardner, P.E.
W. Zachary Crouch, P.E.
Michael E. Wheedleton, AIA, LEED GA
Jason P. Loar, P.E.
Jamie L. Sechler, P.E.

**AUTOMATED METERING INFRASTRUCTURE
FULL-SERVICE IMPLEMENTATION AND MAINTENANCE PROGRAM
TOWN OF GEORGETOWN
SUSSEX COUNTY, DELAWARE
DBF Contract No. 0319A078.000**

APRIL 14, 2023

ADDENDUM NO. 2

The following items shall become a part of the contract documents. Contractor must acknowledge receipt of this addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification.

Item No. 1 The following changes are made to the Public Notice – Services for Water Meter System Replacement (SOQ) document:

- Page 2** I. Overview of Project
- c. *Add after last sentence:* “The town prefers a quick response time and will consider a response time longer than 3 hours.”
- Page 4** II. Submittal Format
- e. Full Service Program Capabilities
- iv. *Replace with* “Proposals for AMR/Drive-by or Hybrid AMI/AMR systems shall NOT be allowed. Systems with repeaters will be considered.
- Page 5** III. Maintenance Program
- Add under item a:*
- vi. For bid item 13, proposer shall include the cost for an annual maintenance program that includes field labor, network, water meters, AMI endpoints, software maintenance, full service data hosting, daily monitoring, backhaul communication fees, annual maintenance contracts, customer portal user fees and any other annual fees that the Town may incur on an annual basis. The proposal shall provide the budgetary annual inflation factor for the maintenance program on a per year basis.

- Page 6** IV. Fixed Network Advanced Metering Infrastructure (AMI) System Specifications.
- a. *Add at the end:* “The Town prefers a fixed network but will consider a LoRaWan NaaS network.”
 - f. *Replace with:* “The town prefers not to use repeaters unless the study determines that the system will not function or be reliable without them.

- Page 11** VI. Meter Specifications
- a. The residential and light commercial meters will comply with the following specifications:
 - i. *Add:* “C708 for 5/8” to 2” residential and light commercial meters.
 - v. *Replace first sentence with:* “The meter electronic register enclosure shall be constructed of a durable engineered composite designed to last the life of the meter.”
- Add:* “c. Selected proposer shall perform an existing meter survey of 100% of the Town’s meters to confirm size, location and other pertinent information that may impact its integration into the AMI system.”

Page 14 *Add:* “XVI. Continuity Plan. The SUBMITTER shall be responsible for fully executing on the full length of the program regardless of their relationship (future) with the meter manufacturer or AMI system provider chosen at the time of execution.

Page 15 Exhibit 1

Key Technology Qualifications: *Remove* “Gas and Electric”

END OF ADDENDUM